# Safety Action Notice



Reference

SAN(SC)20/05

Issued 07 April 2020

Review Date 07 April 2021

# Protection of hospital oxygen pipeline systems through managed distribution of oxygen-dependent patients (COVID-19)

Source: This notice is based on the English Estates and Facilities Alert NHSE/I - 2020/002 issued by NHS Improvement.

## **Summary**

The performance of hospital oxygen pipeline systems will be compromised if the demand from oxygen-dependent patients exceeds their design limits. Clinicians, managers and engineers should collaborate on the safe distribution of patients across healthcare facilities.

### **Action**

- Approved guidance must be followed to achieve maximum sustainable flow from existing installations. Unapproved procedures may cause permanent damage, and there may be no spares available to repair.
- All oxygen alarms should be followed up without delay.
- Ensure that there are suitable arrangements to maintain piped oxygen supply in the case of an emergency, e.g. back up tanks, provision of a mobile unit, etc.
- Plan for emergencies, including the potential for relocating patients to another facility if your system is nearing capacity.
- Clinicians and managers must engage with their engineers in order to safely look after their patients and plan their surge capacity. Health boards will have an Approved Person and Authorising Engineer for Medical Gasses.
- Area and regional leads must collaborate with individual hospitals to manage the location
  of patients that require oxygen and ensure this is considered when planning mutual aid,
  i.e. transfers between hospitals to increase capacity for patient care. This will help to
  ensure that critical oxygen systems are not damaged, compromising patient safety and
  the whole hospital.

#### **Action by**

Chief Executives, Medical Directors and Directors of Estates and Facilities

#### Deadlines for action

Actions underway: Immediate

FAC406-010, v5 Page 1 of 2

Reference: SAN(SC)20/05 Issued: 07 April 2020 Review Date: 07 April 2021

# Problem / background

Every patient requiring O<sub>2</sub> on wards draws on the oxygen storage tank. With hospitals now treating a large proportion of their inpatients for COVID-19 infection, the draw is exceptionally high. The result is that some hospitals are drawing more oxygen from their tanks than the maximum flow for which they were designed.

This carries the risk of icing that could cause flow to drop unexpectedly, compromising supply to patients and/or permanent damage to the system.

### **Distribution**

Ambulance Services Health & Safety Operating Departments

Capital Planning & Pharmacy Hospices

Design Intensive Therapy Units Respiratory Medicine Risk Management Critical care Medical **Medical Physics** Supplies/Procurement **Emergency Department** 

**Estates and Facilities** Nursing

#### Resources

1. BOC - Management of Bulk Medical Oxygen Systems Advice on Pipework pressure and vaporisation.pptx

2. Air Products - Increased Demand on Medical Oxygen Supply Systems MANAGING ICE **BUILD UP** 

Increased Demand on Medical Oxygen Systems March 2020\_FINAL\_2.1.pdf

# **Enquiries**

Enquiries (and adverse incident reports) in Scotland should be addressed to:

#### **Incident Reporting & Investigation Centre (IRIC)**

NHS National Services Scotland Gyle Square, 1 South Gyle Crescent, Edinburgh EH12 9EB

Tel: 0131 275 7575 Email: nss.iric@nhs.scot

Report options are available on the HFS website: How to report an Adverse Incident Further information about reporting incidents can be found in CEL 43 (2009) or by contacting IRIC at the above address.

NHS National Services Scotland is the common name for the Common Services Agency for the Scottish Health Service.

© Crown Copyright 2020 Addressees may take copies for distribution within their own organisations

FAC406-010, v5 Page 2 of 2